



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: Highline

School Name: Marine Technology Center

School Code: NA

School Address: 13201 16th Ave SW, Burien Washington 98166

Number of Samples Collected: 4

Date Collected: 03/21/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
21301	FirstDraw	Bubbler	Downstairs Garage	3	03/30/2019	
21302	FirstDraw	Bubbler	Upstairs next to bathrooms	6	05/28/2019	
21303	FirstDraw	Tap	Upstairs kitchenette	2	05/28/2019	Left
21304	FirstDraw	Tap	Upstairs kitchenette	3	05/28/2019	Right